

ADDENDUM #1

To: All Bidders
Prepared by: Chris Huntress
Huntress Associates, Inc.

Project: Blocksidge Field - Synthetic Turf
Date: February 3, 2017

Cc: Gino Cresta, DPW Director
Issue No. 1

This is an Addendum to the original Construction Documents issued for the Blocksidge Field Synthetic Turf project, Dated January 15, 2017. In all other respects, the terms of the original documents will remain in full effect. However, if there is a conflict between this Addendum and the original specifications, the terms of this Addendum will prevail.

This addendum must be acknowledged on the form for general bid.

1.0 Section 32 18 23.29 SYNTHETIC TURF SPORTS SURFACING

ADD paragraph 2.01 M(5) Additional Acceptable Infilled Turf Synthetic Turf Systems
5. ACT Global Extreme Turf BDX4 (46oz/sy) (978) 404-1789

ADD paragraph 2.03 (5) Additional Acceptable Infill Material Provider
5. Safeshell as manufactured by USGreentech LLC
a. Blend of organic material and rounded silica sand, as recommended by manufacturer.

2.0 Section 32 18 23.31 SYNTHETIC FIELD UNDERLAYMENT

ADD paragraph 5.0 (8)
8. Should the field Gmax average be greater than 135 G's during the 16 year term of the product warranty the manufacturer must pay the cost of repair and remediation of those areas that exceed 135 G's and a full field inspection, refurbishment, and re-testing to ensure compliance with this section.

ADD Approved Products - Additional Acceptable Provider
2. Description: Resilient Thermal Bonded Cross-linked Polyethylene Foam Shock Pad Material ProPlay-Sport20, as manufactured by Schmitz Foam Products
Telephone: (706) 264-8708

Product format:

Size: 36 x 90 inches interlocking panels.
Area: Net coverage per panel 22.5 ft²
Thickness: 0.79" (20mm) +/-

Panel Weight: 0.61 lbs / sf +/-

3.0 Section 00 21 13 INSTRUCTIONS TO BIDDERS

REPLACE paragraph 1.05 (9) with the following

9. General Bid Submission: Submit one copy of bid forms and bid deposit, in a sealed envelop. Clearly and boldly identify envelope with: 1) name of the project; 2) the name of the Awarding Authority; 3) the name, business address, and business telephone number of the bidder; and 4) "General Bid Enclosed". Submit bids as specified in the Advertisement to Bids.

4.0 Questions Received to Date:

- Q1. *Section 1.02 Description of work, Item B, includes a reference to cast-in-place concrete. Do you want the synthetic turf contractor to install the pre-cast concrete turf anchor?*
A1. No. That work with be provided by others.

- Q2. *Section 3.02 of the Turf Specifications reads "the Contractor or the Infilled Synthetic Turf System Vendor shall fine grade the Free Draining Base suitably, including proper rolling and compaction. The Free Draining Base shall not be approved for tolerance to grade without obtaining a topographic survey." can you please confirm whether it is the responsibility of Infilled Synthetic Turf System Vendor or the Site Contractor for fine grading the Free Draining Base, as well as providing the topographic survey?*
A2. The installation of the base stone, including all fine grading, laser grading, compaction and as-built requirements will be provided by others and are NOT part of this contract. The Turf Contractor is responsible to review and provide comment on the base prior to final acceptance, as outlined in the project specification.

- Q3. *Section 3.07 Field Groomer and Sweeper. Can you please confirm that the Synthetic Turf System Vendor is responsible for providing these 2 machines to the owner?*
A3. Correct, The turf field grooming equipment is part of this contract.

- Q4. *Can you please confirm that the Sealed Bids are to be delivered to the Salem City Hall Purchasing Agent?*
A4. Sealed bids are to be delivered to Salem City Hall - Office of the Designated Purchasing Agent - 93 Washington Street, 2nd Floor - Salem, MA 0197, as outlined in the record documents.

END OF ADDENDUM
